


# Erie Boiler Boss

## PRODUCT SAFETY NOTICE

BB2400 and BB1200 Boiler  
Operating Reset Control



Our number one priority is the safety of our people, our customers and our products. Because of this, we are working in cooperation with the Consumer Product Safety Commission on a *voluntary recall* of our Erie Boiler Boss BB2400 and BB1200 Boiler Operating Reset Control manufactured prior to November 17, 2006.

There is a possibility for overheating of the domestic hot water supply or in-system pipe damage due to overheating. This may result in the potential for PERSONAL INJURY OR PROPERTY DAMAGE.

This notice is applicable **ONLY** to the Erie Boiler Boss catalog numbers listed below, manufactured prior to November 17, 2006.

BB2400-1	B2400-2	BB2400-3
BB2400-4	BB2400-5	BB1200

If you suspect you may have a product affected by this notice, please call Schneider Electric between 8:00 a.m. and 4:30 p.m. CT Monday through Friday for more information about the affected controllers and obtaining a replacement product.

The toll-free number is 1-866-692-1110  
[www.schneider-electric.com/buildings](http://www.schneider-electric.com/buildings)

